



Worksite: _____ Instructor: _____ Date/Time: _____

Topic C743: Fire Extinguisher Tag (How to Read)

Introduction: All employees should receive annual training on the use of fire extinguishers. Make sure the extinguisher is ready for use.

Holes are punched on the tag to designate service performed.

FIRE EXTINGUISHER

DO NOT REMOVE SERVICE TAG

FOR CITY, STATE, AND FIRE INSURANCE INSPECTION

LICENSE NO. _____
SERVICED BY _____

ABC (DRY CHEMICAL)	WATER
BC (DRY CHEMICAL)	LOADED STREAM
CARBON DIOXIDE	PURPLE K (PK)
AFFF/FFFP	HALOTRON
FE-36	HALON 1211
CLASS D	WET CHEM
WATER MIST	INERGEN
HALON 1301	CLEAN AGENT
FE-13 SYSTEM	FM2000

2007/2008/2009

SERVICED			NEW			RECHARGED		
DEC	NOV	OCT	AUG	JULY	JUNE	MAY	APR	MAR
		SEP						FEB
								JAN



HOLE SHOWS THE TYPE OF FIRE EXTINGUISHER

HOLE SHOWS THE YEAR OF LAST SERVICE/INSPECTION

HOLE SHOWS THE TYPE OF SERVICE/INSPECTION

HOLE SHOWS THE MONTH OF SERVICE/INSPECTION

Fire Extinguishers should be visually inspected periodically for any defects in hardware as well as inner pressure. An annual inspection of all fire extinguishers must be done to ensure the correct pressure is maintained to propel the suppressant, as well as ensure the Fire Extinguisher has no defects, rust, broken or missing hoses, and is in good working condition.

Employee Attendance: (Names or signatures of personnel who are attending this meeting)

These guidelines do not supersede local, state, or federal regulations and must not be construed as a substitute for, or legal interpretation of, any OSHA regulations

Lugar de trabajo: _____ Instructor: _____ Fecha/Hora: _____

Tópico C743: Etiqueta del Extintor de Incendios (Como Leerla)

Introducción: Todos los empleados deben recibir un entrenamiento anual en el uso de los extintores de incendios. Asegúrese que los extintores estén listos para ser usados. Se le hacen hoyos a la etiqueta para designar el servicio realizado.

EL HOYO MUESTRA EL TIPO DE EXTINTOR QUE ES

EL HOYO MUESTRA EL AÑO DE LA ÚLTIMA INSPECCIÓN O SERVICIO

EL HOYO MUESTRA EL TIPO DE INSPECCIÓN O SERVICIO

EL HOYO MUESTRA EL MES DEL SERVICIO O INSPECCIÓN

EXTINTOR DE INCENDIOS
ETIQUETA DE SERVICIO

NO LA QUITE INSPECCIÓN PARA LA CIUDAD, EL ESTADO O EL SEGURO DE INCENDIOS

NUMERO DE LICENCIA _____
REVISADA POR _____

ABC (QUÍMICO SECO)	AGUA
BC (QUÍMICO SECO)	CORRIENTE CARGADA
DIÓXIDO DE CARBONO	PURPLE K (PK)
AFFF/FFFP	HALOTRON
FE-36	HALON 1211
CLASE D	QUÍMICO HÚMEDO
NIEBLA DE AGUA	INERGEN
HALON 1301	AGENTE LIMPIO
FE-13	FM2000
SISTEMA	

2007/2008/2009

SERVICIADO			NUEVO			RECARGADO		
DIC	NOV	OCT	SEP	AGO	JUL	JUN	MAY	ABR
								MAR
								FEB
								ENE

Los extintores de incendios deben de ser visualmente inspeccionados periódicamente para ver que no haya ningún defecto así como la presión interna. Una inspección anual de todos los extintores debe ser realizada para asegurarse que se mantenga la presión correcta para propulsar el supresor, así como para asegurarse que el extintor no esté defectuoso, oxidado, roto o tenga una manguera perdida y este en buena condición de

Se requiere que, durante cada inspección, una persona calificada o competente inspeccione:
